

ATTESTATION OF CONFORMITY (No. 40000042269)

A Phoenix Mecano Company

ROSE Systemtechnik GmbH, Erbeweg 13-15, D-32457 Porta Westfalica

declares in its sole responsibility, that the product:

ROSE-Ex empty enclosure			
Component	UK Type Examination Certificate	Type	Degree of protection
EJB Series	CML 21UKEX1480U	EJB 01 / 02 / 03 / 04 / 06 / 07 / 09 / 10	IP66

is in conformity with the relevant UK statutory requirements:

SI 2016 No. 1107

References to the UK statutory requirements used or references to the other technical specifications in relation to which conformity is attested:

EN IEC 60079-0:2018

EN 60079-1:2014

EN 60079-31:2014

Marking:II 2 G Ex db IIB+H₂ Gb or

II 2 G Ex db IIB Gb



II 2 D Ex tb IIIC Db

Approved body of the UK Type Examination Certificates:

Eurofins E&E CML Limited [2503]

Newport Business Park

New Port Road, Ellesmere Port

CH65 4LZ

Approved body to quality evaluation:

Eurofins E&E CML Limited [2503]

Newport Business Park

New Port Road, Ellesmere Port

CH65 4LZ

For the safe use of this apparatus, the information given in the accompanying operating instructions must be followed.

Porta Westfalica, 2023-05-11
Place and datei. A. A. Brandhorst
Ex authorized representative