

ATTESTATION OF CONFORMITY (No. 40000042277)

A Phoenix Mecano Company

ROSE Systemtechnik GmbH, Erbeweg 13-15, D-32457 Porta Westfalica

declares in its sole responsibility, that the product:

ROSE-Ex empty enclosure			
Material	UK Type Examination Certificate	Type	Degree of protection
Aluminium	CML 21UKEX3586U	25.xx xx xx	IP66
Polyester	CML 21UKEX3584U	26.xx xx xx	IP66
Stainless steel	CML 21UKEX3513U	34.xx xx xx R3/R4xxxxxxxxx	IP66

is in conformity with the relevant UK statutory requirements:

SI 2016 No. 1107

References to the UK statutory requirements used or references to the other technical specifications in relation to which conformity is attested:

EN IEC 60079-0:2018
EN IEC 60079-7:2015/A1:2018
EN 60079-31:2014**Marking:**

II 2 G Ex eb IIC Gb

II 2 D Ex tb IIIC Db

Approved body of the UK Type Examination Certificates:

Eurofins E&E CML Limited [2503]
Newport Business Park
New Port Road, Ellesmere Port
CH65 4LZ

Approved body to quality evaluation:

Eurofins E&E CML Limited [2503]
Newport Business Park
New Port Road, Ellesmere Port
CH65 4LZ

For the safe use of this apparatus, the information given in the accompanying operating instructions must be followed.

Porta Westfalica, 2023-05-11
Place and datei. A. A. Brandhorst
Ex authorized representative