UK DECLARATION OF CONFORMITY



ROSE Systemtechnik GmbH, Erbeweg 13-15, D-32457 Porta Westfalica

declares in its sole responsibility, that the product:

ROSE-Ex power distribution, switchgear and control assembly		
Component	UK-type examination certificate	Туре
IJB Series	CML 21 UKEX 1483X	IJB 01, 02, 03, 04, 05, 06

is in conformity with the relevant UK statutory requirements:

SI2016No.1107

References to the UK statutory requirements used or references to the other technical specifications in relation to which conformity is declared:

EN IEC 60079-0:2018 EN 60079-1:2014 EN 60079-31:2014

Marking:[1]

🖾 II 2 G Ex db ... IIB T4, T5 or T6 Gb or

ⓑ II 2 D Ex tb ... IIIC T85°C, T100°C or T135°C Db

[1] Ignition protection, ambient temperature, temperature classification and IP rating may vary. For applied marking see specific equipment label

Approved body of the UK type examination certificates:

Eurofins E&E CML Limited
[2503]
Newport Business Park
New Port Road
Ellesmere Port CH65 4LZ

Approved body to quality evaluation:

Eurofins E&E CML Limited
[2503]
Newport Business Park
New Port Road
Ellesmere Port CH65 4LZ

For the safe use of this apparatus, the information given in the accompanying operating instructions must be followed.

Porta Westfalica, 2021-07-23

Part number: 40000042274 REV 0

Place and date

A A Brandhorst