UK DECLARATION OF CONFORMITY



ROSE Systemtechnik GmbH, Erbeweg 13-15, D-32457 Porta Westfalica

declares in its sole responsibility, that the product:

	ROSE-Ex power distribution, switchgear and control assembly
Material	UK-type examination certificate
Aluminium	CML 21UKEX3586U
Polyester	CML 21UKEX3584U
Stainless steel	CML 21UKEX3513U

is in conformity with the relevant UK statutory requirements:

SI2016No.1107

References to the UK statutory requirements used or references to the EN IEC 60079-0:2018/AC:2020 other technical specifications in relation to which conformity is declared:

EN IEC 60079-7/A1:2018 EN 60079-31:2014

Marking:[1]

(Ex) II 2 G Ex eb IIC Gb

(Ex) II 2 D Ex tb IIIC Db

[1] Ignition protection, ambient temperature, temperature classification and IP rating may vary. For applied marking see specific equipment label

Approved body of the UK type examination certificates:

Eurofins E&E CML Limited [2503] **Newport Business Park** New Port Road Ellesmere Port CH65 4LZ

Approved body to quality evaluation:

Eurofins E&E CML Limited [2503] **Newport Business Park New Port Road** Ellesmere Port CH65 4LZ

For the safe use of this apparatus, the information given in the accompanying operating instructions must be followed.

Porta Westfalica, 2021-07-21

Part number: 40000042277 REV.0

Place and date

i. A. A. Brandhorst