UK DECLARATION OF CONFORMITY



ROSE Systemtechnik GmbH, Erbeweg 13-15, D-32457 Porta Westfalica

declares in its sole responsibility, that the product:

ROSE-Ex power distribution, switchgear and control assembly	
Material	UK-type examination certificate
Aluminium	CML 21UKEX1585X
Polyester	CML 21UKEX1582
Stainless steel	CML 21UKEX1583

is in conformity with the relevant UK statutory requirements:

SI2016No.1107

References to the UK statutory requirements used or references to the other technical specifications in relation to which conformity is declared:

EN IEC 60079-0:2018 EN IEC 60079-7/A1:2018 EN 60079-11:2012 EN 60079-31:2014

Marking:[1]

(a) II 2 G Ex eb db ia [ia] mb IIC T6, T5, T4 Gb

UK 2503

⟨Ex⟩

II 2 D Ex tb IIIC T85 °C, T100 °C, T135 °C Db IP66/IP65

UK 2503

[1] Ignition protection, ambient temperature, temperature classification and IP rating may vary. For applied marking see specific equipment label

Approved body of the UK type examination certificates:

Eurofins E&E CML Limited
[2503]
Newport Business Park
New Port Road
Ellesmere Port CH65 4LZ

Approved body to quality evaluation:

Eurofins E&E CML Limited
[2503]
Newport Business Park
New Port Road
Ellesmere Port CH65 4LZ

For the safe use of this apparatus, the information given in the accompanying operating instructions must be followed.

Porta Westfalica, 2021-07-21

Place and date

i A A Brandhorst

Page 1/2

