



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2020312313000292

Applicant ROSE Systemtechnik GmbH
Address Erbeweg 13 - 15, 32457 Porta Westfalica, Germany
Manufacturer ROSE Systemtechnik GmbH
Address Erbeweg 13 - 15, 32457 Porta Westfalica, Germany
Production Factory Phoenix Mecano S.E. Asia Pte. Ltd.
Production Address 53 Ubi Ave 3#04-01, Travelite Building, Singapore 408863
Product Empty enclosure
Model/Type Type 25.*****
Ex marking Ex eb IIC Gb , Ex tb IIIC Db
Reference Standards GB/T 3836.1-2021 , GB/T 3836.3-2021 , GB/T 3836.31-2021
Certification mode Type Test + Initial Factory Inspection + Post-Certification Surveillance

The product(s) is verified and certified according to CNCA-C23-01: 2019 *China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product* and CNEX-C2301-2019 *Guideline of China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product*.

See Annex for the detailed product information (2 pages)

Initial issue date: 2020-10-28

Issued date: 2023-11-27

Valid to: 2025-10-27

The validity of this certificate is maintained through the regular supervision of the issuing authority during the validity period.

Where any discrepancy arises between the English translation and the original Chinese version, the Chinese version shall prevail.

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.



中国认可
产品
PRODUCT
CNAS C208-P

<http://www.ccc-cnex.com>
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China P.C.: 473008
Tel: 0377-63239734 Email: ccc@cn-ex.com

CN0000103DZ



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No. : 2020312313000292

Page 1 of 2

Product information:

1. This certificate covers the following models:

Nomenclature:

25.	**	**	**
(1)	(2)	(3)	(4)

- (1): Material aluminium
(2): Height
(3): Width
(4): Depth

- Type 25.*****

sizes	Length	width	depth
min	58mm	64mm	34mm
max	600mm	600mm	227mm

Ambient temperature:

- 55 °C to +135 °C with Silicon gasket
- 40 °C to +100 °C with HF gasket
- 40 °C to +100 °C with PU-foam
- 20 °C to + 85 °C with CR gasket
- 20 °C to +100 °C with window out of glas
- 50 °C to +100 °C with PC-window mono duro clear 8099, conductive

Ingress protection: IP66

Thread stud of the earth bolt compl: M6x60, M8x50, M10x60, M12x80

Ex marking: Ex eb IIC Gb , Ex tb IIIC Db

Issued date: 2023-11-27

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No. : 2020312313000292

Page 2 of 2

- Producers should organize production in accordance with the technical documents approved by the certification body.
- 2. Specific conditions of safety use:
 - The empty enclosure with a coating must not be used in areas affected by charge-producing processes, mechanical friction and separation processes, electron emission (e.g. in the vicinity of electrostatic coating equipment), and pneumatically conveyed dust.
 - Installation of electrical components requires a further assessment by an ExCB.
 - See instruction for other information.
- 3. Certificate related report(s):
 - Type test report: CQST2006C007G, CQST2006C007G/01
- 4. Certificate change information:
 - 1st change on January 14, 2023: Updated the standards for certification.
 - 2nd change on November 27, 2023: Changed the address name of the Production Factory.

Issued date: 2023-11-27

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.

