



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312313000401

Applicant	ROSE Systemtechnik GmbH
Address	Erbeweg 13-15, 32457 Porta Westfalica, Germany
Manufacturer	ROSE Systemtechnik GmbH
Address	Erbeweg 13-15, 32457 Porta Westfalica, Germany
Production Factory	Phoenix Mecano India Pvt Ltd.
Production Address	Plant -I & II, Pirangut Industrial Area, Post Gohotawade, Plot 388/389, Village Bhare, Taluka Mulshi, Dist-Pune - 412115, India
Product	Enclosure
Model/Type	EJB**
Ex marking	Ex d IIB + H ₂ Gb, Ex d IIB Gb, Ex tD A21 IP66
Reference Standards	GB3836.1-2010, GB3836.2-2010, GB12476.1-2013, GB12476.5-2013

Certification mode Type Test + Initial Factory Inspection + Post-Certification Surveillance

The product(s) is verified and certified according to CNCA-C23-01: 2019 *China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product* and CNEC-C2301-2019 *Guideline of China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product*.

See Annex for the detailed product information (3 pages)

Issued on: 2021-06-16

Valid to: 2026-06-15

The validity of this certificate is maintained through the regular supervision of the issuing authority during the validity period.

Where any discrepancy arises between the English translation and the original Chinese version, the Chinese version shall prevail.

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co., Ltd.



<http://www.ccc-cnex.com>
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China P.C.: 473008
Tel: 0377-63239734 Email: ccc@cn-ex.com

CN 0000716



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

(Annex)

No.: 2021312313000401

Page 1 of 3

Product information:

1. This certificate covers the following models:

- EJB**

For detailed Model/Type: EJB 01, EJB 02, EJB 03, EJB 04, EJB 06, EJB 07, EJB 09, EJB 10

Ingress protection: IP66

Technical data:

The relation between enclosure type, temperature class, maximum surface temperature, maximum ambient temperature and maximum allowed power dissipation is given in the table below.

Temperature class	T6			T5					T4				
Max. surface temperature	T85 °C			T100 °C					T135 °C				
Max. ambient temperature (°C)	40	50	60	40	50	55	60	75	40	50	60	90	110
EJB Type	Maximum allowed power dissipation (W)												
EJB 01	60	-	36	-	-	60	-	36	-	-	-	60	36
EJB 02	76	-	42	-	-	76	-	42	-	-	-	76	42
EJB 03	87	-	60	-	-	87	-	60	-	-	-	87	60
EJB 04	190	150	105	292	230	190	185	105	530	455	390	190	105
EJB 06	209	166	114	338	260	209	206	114	584	514	436	209	114
EJB 07	365	290	205	570	440	365	320	205	1050	890	760	365	205
EJB 09	467	319	236	728	555	467	353	236	1238	1145	956	467	236
EJB 10	726	568	400	1085	864	726	712	400	2038	1709	1454	726	400

Ex marking: Ex d IIB + H₂ Gb, Ex d IIB Gb, Ex tD A21 IP66

- Producers should organize production in accordance with the technical documents approved by the certification body.

Issued on: 2021-06-16

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co.,Ltd.



中国认可
产品
PRODUCT
CNAS C208-P



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

(Annex)

No.: 2021312313000401

Page 2 of 3

2. Specific conditions of safety use:

- Technical data

Enclosure Type	Service temperature range	Ambient temperature range
EJB 01 ... EJB 04 and EJB 07 - without window - with window, extended thickness	-60°C to +135°C	-60°C to +110°C
EJB 01 ... EJB 04 and EJB 07 - with window, normal thickness EJB 06, 09 and 10	-20°C to +135°C	-20°C to +110°C

- For enclosures provided with a powder coating or liquid painting and intended for use in dust Group applications, the user shall minimize the risk from electrostatic discharge by suitable selection and installation.
- The maximum number of apertures, their maximum sizes and their positions are specified in the instruction manual IM.EJB.U.
- Oil-filled circuit-breakers and contactors shall not be used.
- The content of the EJB enclosure may be placed in any arrangement provided that an area of at least 20 % (Group IIB) or 40 % (H₂) of each cross-sectional area remains free. Separate relief areas may be aggregated provided that each area has a minimum dimension in any direction of 12.5 mm.
- The flame path of the cover differs from the values stated in GB3836.2. Contact the manufacturer for information on the dimensions of the flameproof joints.
- The M6, M8, M10 and M12 fasteners are of grade A2-70 with a yield stress of at least 450 MPa and shall be applied with a minimum torque value of 11 Nm (M6), 28 Nm (M8), 58 Nm (M10) and 95 Nm (M12).
- See instruction for other information.

3. Certificate related report(s):

Issued on: 2021-06-16

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.



中国认可
产品
PRODUCT
CNAS C208-P



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION (Annex)

No.: 2021312313000401

Page 3 of 3

- Type test report: CQST2105C019
- Factory inspection report: CN2020Q010227

4. Certificate change information: None

Issued on: 2021-06-16

Director:

穆大玉



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.



中国认可
产品
PRODUCT
CNAS C208-P