



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2021312304001062

Applicant ROSE Systemtechnik GmbH
Address Erbeweg 13-15, 32457 Porta Westfalica, Germany
Manufacturer ROSE Systemtechnik GmbH
Address Erbeweg 13-15, 32457 Porta Westfalica, Germany
Production Factory Phoenix Mecano India Pvt Ltd.
Production Address Plant -I & II, Pirangut Industrial Area, Post Gohotawade, Plot 388/389, Village Bhare, Taluka Mulshi, Dist-Pune - 412115, India
Product Control box
Model/Type TBE*****
Ex marking Ex d IIB T4/T5/T6 Gb, Ex d IIC T4/T5/T6 Gb,
Ex tD A21 IP66 T85°C/T100°C/T135°C
Reference Standards GB3836.1-2010, GB3836.2-2010, GB12476.1-2013,
GB12476.5-2013

Certification mode Type Test + Initial Factory Inspection + Post-Certification Surveillance

The product(s) is verified and certified according to CNCA-C23-01: 2019 *China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product* and CNEX-C2301-2019 *Guideline of China Compulsory Certification Implementation Rule on Explosion Protected Electrical Product*.

See Annex for the detailed product information (3 pages)

Issued on: 2021-05-21

Valid to: 2026-05-20

The validity of this certificate is maintained through the regular supervision of the issuing authority during the validity period.

Where any discrepancy arises between the English translation and the original Chinese version, the Chinese version shall prevail.

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co., Ltd.



中国认可
产品
PRODUCT
CNAS C208-P

<http://www.ccc-cnex.com>
ccc.china-ex.com

Add: No. 20, North Zhongjing Road, Nanyang, Henan, P. R. China
Tel: 0377-63239734

P.C.: 473008
Email: ccc@cn-ex.com

CN 0000668



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

(Annex)

No.: 2021312304001062

Page 1 of 3

Product information:

1. This certificate covers the following models:

- TBE*****

The TBE series consists of 6 types:

TBE 100T, TBE 130T and TBE 160T: enclosures in 3 different sizes, without display window

TBE 100TW, TBE 130TW and TBE 160 TW: enclosures in 3 different sizes, with display window

Ingress protection: IP66

Electrical ratings:

The electrical ratings are dependent on the built-in components and equipment, but do not exceed 1.1 kV ac/dc nominal, 125 A and 35 mm². Actual ratings are stated on the nameplate.

Options:

The threaded flamepaths may be provided with a max. 0.008 mm thick electro-plating.

The enclosures may be supplied in natural finish, electro-plated, powder coated or liquid painted. The painting thickness does not exceed 0.18 mm.

Thermal data:

The relation between enclosure type, temperature class, maximum surface temperature, maximum ambient temperature and maximum allowed power dissipation is given in the table below.

Type	Dimensions	Temperature	T6	T5	T4	T6	T5	T4
TBE	(H x W x	class						

Issued on: 2021-05-21

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.



中国认可
产品
PRODUCT
CNAS C208-P



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

(Annex)

No.: 2021312304001062

Page 2 of 3

	D)(mm)	Maximum surface temperature	T85 °C	T100 °C	T135 °C	T85 °C	T100 °C	T135 °C
		Maximum ambient temperature	+40 °C	+55 °C	+90 °C	+60 °C	+75 °C	+110 °C
100T	130 x 116 x 98	Maximum allowed power dissipation	20 W			12 W		
130T	160 x 148 x 107		29 W			15 W		
160T	190 x 180 x 116		41 W			24 W		
100TW	130 x 116 x 110		20 W		-	12 W		-
130TW	160 x 148 x 124		29 W		-	15 W		-
160TW	190 x 180 x 134		41 W		-	24 W		-

* : values have been determined without a dust layer

Ex marking: Ex d IIB T4/T5/T6 Gb, Ex d IIC T4/T5/T6 Gb,

Ex tD A21 IP66 T85 °C/T100 °C/T135 °C

The equipment is marked with Group IIB if at least 20% of each internal cross-sectional area remains free; it may be marked with Group IIC if at least 40% of each internal cross-sectional area remains free.

- Producers should organize production in accordance with the technical documents approved by the certification body.

2. Specific conditions of safety use:

- Ambient temperature range

Maximum ambient temperature range (for details see table above):

Issued on: 2021-05-21

Director:



Nanyang Explosion Protected Electrical Apparatus Research Institute Co., Ltd.



中国认可
产品
PRODUCT
CNAS C208-P



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

(Annex)

No.: 2021312304001062

Page 3 of 3

Enclosure without display window: -60°C to +110°C

Enclosure with 12 mm thick display window: -60°C to +75°C

Enclosure with 8 mm thick display window: -20°C to +75°C

- For enclosures provided with a powder coating, liquid painting or provided with a non-metallic nameplate and/or tagplate intended for use in dust Group applications, the user shall minimize the risk from electrostatic discharge by suitable selection and installation.
- The threaded flame path of the cover is more than required by GB3836.2. Contact the manufacturer for information on the dimensions of the flameproof joints.
- See instruction for other information.

3. Certificate related report(s):

- Type test report: CQST2010C046
- Factory inspection report: CN2020Q010227

4. Certificate change information: None

Issued on: 2021-05-21

Director:



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.

