

Rea No: 1999/027771/07

(Pty) Ltd

7 Spanner Rd / PO Box 467 Olifantsfontein

Tel: +27 (11) 316 4601 Fax: +27 (11) 316 5670

E-mail: admin-mgr@explolabs.co.za

GOVERNMENT APPROVED TEST LABORATORY

IN TERMS OF ARP 0108: "REGULATORY REQUIREMENTS FOR EXPLOSION PROTECTED APPARATUS"

IA CERTIFICATE

Date Issued: *Expiry date: 05 Jan 2022 05 Jan 2025

Page 1 of 6 Issue: 4

Ex - Type Examination Certificate

Certificate Number:

S-XPL/12.0778

Equipment:

Connection and Junction Box and Control Box

Model / Type: Applicant:

06. XX XX XX and 16. XX XX XX Rose Systemtechnik GmbH

Postfach 1362

D-32439

Porta Westfalica

Manufacturer: Serial No:

ROSE Systemtechnik GmbH

All serial numbers imported between issued- and expire date and all serial

numbers covered by a valid report or acceptable product certification mark.

Supplied by Rose Systemtechnik GmbH Identified by Inspection Authority number S-XPL/12.0778

And as described in the Explolabs file number XPL/13351/12.0778 is hereby certified "Explosion Protected (Refer to clause 1, for Ex Rating)", having been examined and inspected in accordance with the relevant requirements of South African Standards.

IEC/SANS 60079-0: 2017	Explosive atmospheres Part 0: Equipment — General requirements			
SANS 60079-1: 2015 Ed 5 IEC 60079-1: 2014 Ed 7				
IEC/SANS 60079-7: 2015	Explosive atmospheres Part 7: Equipment protection by increased safety "e"			
SANS 60079-11: 2012 Ed 4 IEC 60079-11: 2011 Ed 6	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"			
SANS 60079-18: 2017 Ed 4 IEC 60079-18: 2014 Ed 4	Explosive atmospheres Part 18: Equipment protection by encapsulation "m"			
SANS 60079-31: 2014 Ed 2 IEC 60079-31: 2013 Ed 2	Explosive atmospheres Part 31: Equipment dust ignition protection by enclosure "t"			

2 PETICIAIS PETICIAIS

ANNEX TO CERTIFICATE NO S-XPL/12.0778

PAGE 2 OF 6

Risk of ignition provided:

-	Protection afforded	Equipment Protection Level (EPL) Group	Performance of protection	Conditions of operation	T class or Max Surface Temp (°C)
of Persons person	High	Gb Group II	Suitable for normal operation and frequently occurring disturbances or equipment where faults are normally taken into account	Equipment remains functioning in zones 1 and 2	T6 (85°C) T5 (100°C) T4 (135°C)
	High	Db Group III	Suitable for normal operation and frequently occurring disturbances or equipment where faults are normally taken into account	Equipment remains functioning in zones 21 and 22	T85°C T100° C T135°C

1. GENERAL

The marking of the Connection and Junction Box and Control Box shall include the following:

Ex db, eb ia [ia] mb IIC T6, T5, T4 Gb; Ex tb IIIC T85°C, T100°C, T135°C Db

The power distribution, switch and control gear assembly, type 06. XX XX XX and 16.XX XX XX, consists of a polyester enclosure designed to Increased Safety "e" or Protection by Enclosure "tb" type of protection, which can be provided with flanges, if necessary. It is used to accommodate field bus distributors and terminals, and can be provided with actuator elements if necessary. 'Ex' cable glands are used for connection. All installed and attached components are tested and certified with a separate examination certificate.

Technical Data

GENIOIARS GEPIOIARS GEPIOIARS GENIOIARS SPRIOIARS

Ambient temperature:

-55 °C to +90 °C: with gasket out of silicon -40 °C to +90 °C: with gasket out of HF

-40 °C to +90 °C with PU-foam

-20 °C to +85 °C with gasket out of CR -50 °C to +85 °C with window out of PC

-20 °C to +85 °C with window out of glass

Degree of protection: IP66

Technical	Ex	Polyester	Polyester	Polyester	Polyester	Polyester
data	Polyester	Ex Okta	Ex PF	Ex Mini	Ex Polyglas	Ex Combi
	Enclosure	Box	Enclosure	Polyglas		Box
Rated voltage [V]:	Up to 1500	Up to 750	Up to 1500	Up to 1500	Up to 1500	Up to 1500
Rated current [A]:	Max. to 400					
Conductor size [mm²]:	Max. 300	Max. 50	Max. 300	Max. 300	Max. 300	Max. 300
Protective cross section [mm²]:	Max. 150	Max. 25	Max. 150	Max. 150	Max. 150	Max. 150

AZITIONES **ANNEX TO CERTIFICATE NO S-XPL/12.0778**

PAGE 3 OF 6

Nomenclature

XX.	**	**	**
1	2	3	1

- 1: Type, material Polyester
- 2: Length
- 3: Width
- 4: Depth

Enclosure standard and max. Power Dissipation of Ex Polyester Enclosure:

Type reference

Empty enclosure 26.XX XX XX Ex Polyester standard

Increased Safety 06.XX XX XX Ex Polyester standard

Intrinsic Safety / mixed assembled 16.XX XX XX Ex Polyester standard

No.	Product Type	Height [mm]	Width [mm]	Depth [mm]	Max. Power Dissipation [W] (dT 40 °K)
1	XX.08 08 06	75	80	56	5
2	XX.08 08 08	75	80	75	7
3	XX.08 11 06	75	110	56	6
4	XX.08 11 08	75	110	75	8
5	XX.08 16 06	75	160	56	9
6	XX.08 16 08	75	160	75	11
7	XX.08 19 06	75	190	56	10
8	XX.08 19 08	75	190	75	12
9	XX.08 23 06	75	230	56	12
10	XX.08 23 08	75	230	75	14
11	XX.12 12 09	120	122	91	13
12	XX.12 22 09	120	220	91	20
13	XX.16 16 09	160	160	91	19
14	XX.16 26 09	160	260	91	26
15	XX.16 36 09	160	360	91	34
16	XX.16 56 09	160	560	91	49
17	XX.25 26 12	250	255	121	41
18	XX.25 26 16	250	255	161	50
19	XX.25 40 12	250	400	121	57
20	XX.25 40 16	250	400	161	68
21	XX.25 60 12	250	600	121	78
22	XX.36 36 09	360	360	91	58
23	XX.41 40 12	405	400	121	78
24	XX.41 40 20	405	400	201	107

Enclosure standard and max. Power Dissipation of Polyester Ex Okta Box Enclosure:

Type reference

Empty enclosure 26.88 XX XX Ex Okta Box

Increased Safety 06.88 XX XX Ex OktaBox

PERIOLES PERIOLES

ANNEX TO CERTIFICATE NO S-XPL/12.0778

PAGE 4 OF 6

Intrinsic safety/ mixed assembled 16.88 XX XX Ex Okta Box

Enclosure standard and max. Power Dissipation of Polyester Ex PF Enclosure:

Type reference:

Empty enclosure 26.14 XX XX Ex PF Enclosure

Increased Safety 06.14 XX XX Ex PF Enclosure

Intrinsic Safety / mixed assembled 16.14 XX XX Ex PF Enclosure

No.	Product Type	Height [mm]	Width [mm]	Depth [mm]	Max. Power Dissipation [W] (dT 40 °K)
1	XX.XX 01 00	170	270	136	36
2	XX.XX 02 00	270	270	136	49
3	XX.XX 03 00	270	541	136	81

Enclosure standard and max. Power Dissipation of Polyester Ex Mini Polyglas and Ex Polyglas Enclosure:

Type reference:

Type reference:

Empty enclosure 26.XX XX XX Ex Mini Polyglas

Increased Safety 06.XX XX XX Ex Mini Polyglas

Intrinsic Safety / mixed assembled 16.XX XX XX Ex Mini Polyglas

No.	Product Type	Height [mm]	Width [mm]	Depth [mm]	Max. Power Dissipation [W] (dT 40 °K)
1	XX.12 20 00	120	200	100	19
2	XX.16 26 00	160	260	100	26
3	XX.16 34 00	160	340	100	33
4	XX.20 15 00	200	150	100	23
5	XX.20 20 00	200	200	168	39
6	XX.20 30 00	200	300	168	51
7	XX.30 40 00	405	305	202	88
8	XX.40 60 00	605	405	252	163

Enclosure standard and max. Power Dissipation of Ex Polyester Combi Box:

Type reference:

Empty enclosure 26.01 XX XX Ex Combi Box

Increased Safety 06.01 XX XX Ex Combi Box

Intrinsic Safety / mixed assembled

DOCUMENT No: XPL0213 RELEASE DATE: 29/05/2018

This report supersedes all previous documents bearing the reference no XPL/13351/12.0778 Rev 3. ARTICLES ARTICLES

PERIOLIES PERIOLIES

ANNEX TO CERTIFICATE NO S-XPL/12.0778

O S-XPL/12.0778 PAGE 5 OF 6 16.01 XX XX Ex Combi Box

No	Product Type	Height [mm]	Width [mm]	Depth [mm]	Max. Power Dissipation [W] (dT 40 °K)
1	XX.XX 22 15	177	177	145	28
2	XX.XX 24 15	360	177	145	45
3	XX.XX 44 15	360	360	145	70

The rated values are maximum values, the actual electrical values depend on the electrical equipment incorporated. Within the scope of these maximum permissible values and with due regard to the standards, the manufacturer specifies the final rated values dependent on the system conditions, mode of operation, utilization category, etc. The characteristic values of the intrinsically safe circuits are to be given by the manufacturer on his own responsibility. Further technical details have been specified in the test documents.

The composition of the symbol specifying the type of protection depends on the types of protection of the components used.

The maximum permissible ambient temperature range of the terminal housing can be limited by the maximum permissible ambient temperature ranges of the separately certified equipment.

Additional Advices

Components attached or installed (terminal compartments, bushings, Ex-type cable glands, connectors) shall be of a technical standard that at least complies with the specifications on the cover sheet, and they shall have a separate examination certificate. The operating conditions specified in the component certificates must definitely be complied with, and the operating instructions must include a note to inform the operating company of this equipment. The method used for assessing the suitability of the used component must be documented in a verifiable manner in compliance with the QM system.

For repair of separately certified components, the IECEx Examination for these components must be sobserved.

Equipment of the type of protection intrinsic safety "i" according to IEC 60079-11 is to be installed in such a way that the distances, creepage distances und clearances between intrinsically safe circuits and non-intrinsically safe circuits required according to EN 60079-14 are complied with.

When more than one intrinsically safe circuit is used, the rules for interconnection are to be observed.

Degree of protection IP66 will be safeguarded only when sealing and cable entry fittings are properly fitted. The manufacturer's instructions must be followed.

Installation of the components in the electrical apparatus shall be made such that the local temperatures will be within the operating temperature range.

Notes for manufacturing and operation

Each device needs to be evaluated concerning the max. allowed temperature limit according to the relevant temperature class and concerning the limiting temperature of the materials. This evaluation needs to be done within the engineering process and must be complemented by an additional temperature measurement in any case doubt. The admissible ambient temperature ranges of the build-in components may not be exceeded at the place of installation.

Based on the following documentation: IECEx PTB 08.0004 Issue No 5

2. INSTALLATION INSTRUCTIONS

It is the manufacturer's responsibility to supply installation instructions with each unit offered for sale as required by IEC/SANS 60079-0 Clause 30.

SPECIAL CONDITIONS FOR SAFE USE (denoted by "X" after certificate number)
 None

DOCUMENT No: XPL0213 | RELEASE DATE: 29/05/2018 | REV: 7 |
This report supersedes all previous documents bearing the reference no XPL/13351/12.0778 Rev 3

AZPROLIES AZPROLIES

ANNEX TO CERTIFICATE NO S-XPL/12.0778

PAGE 6 OF 6

4. SCHEDULE OF LIMITATIONS (denoted by "U" after certificate number) None

5. CONDITIONS OF CERTIFICATION

All production units must be covered by a QAN (Quality Assurance Notification), Product Mark Scheme or batch evaluation.

MARKING 6.

The following (or similar) information have to be clearly and permanently marked on all units:

Supplier

: Rose Systemtechnik GmbH

Manufacturer

: ROSE Systemtechnik

Equipment

: Connection and Junction Box and Control Box

Model/Type

: 06. XX XX XX and 16. XX XX XX

Serial No.

Ex Rating

: Ex db, eb ia [ia] mb IIC T6, T5, T4 Gb; Ex tb IIIC T85°C, T100°C, T135°C Db

IA Certificate No

: S-XPL/12.0778

This certification indicates compliance with R10.1 of the Mines Health and Safety Act and/or EMR 9(2) of the Occupational Health and Safety Act, provided This certification indicates compilative with KTOLLO the minutes readilities that the apparatus is used as relevant in accordance with:

SANS 10086 and IEC/SANS 61241-14 requirements as applicable;

Any conditions mentioned in the above report;

iii) Any relevant requirements and codes of practice enforced in terms of the Mine Health and Safety Act or Occupational Health and Safety Act;

Any restrictions and conditions enforced by the Chief Inspector of Mines or the Principal Inspector or the Chief Inspector: Occupational Health and Safety.

A revision certificate replaces all previous version of the certificate.

* - Only covers equipment Imported between the "Issued" and "Expire" dates.

If and when your QAN (Quality Assurance Notification) Certificate for your equipment manufacturer expires during the valid period of the IA Certification (issued for your equipment) and a new certificate is not submitted the existing IA Certification will then be cancelled. It is thus the client's responsibility to always submit the updated and valid QAN certificate(s) to Explolabs (Pty) Ltd

Responsible Testing Officer:

K Malibe

Technical Specilaist

EXPLOLABS EXPLOSION PREVENTION SERVICES

This report/certificate shall not be reproduced except in full without the written approval of the company Explolabs (Pty) Ltd shall not be liable for any losses or damages sustained on account of any failure or omission to properly perform our duties in terms of any contract undertaken by us. This disclaimer is immutable and automatically incorporated in any contract undertaken by us; notwithstanding anything to the contrary, save for the express written waiver of our managing director. By marking the equipment in accordance with the documentation/standard, the manufacturer attests on his own responsibility that the equipment has been constructed in accordance with the applicable requirements of the relevant standards and that the routine verifications and tests have been successfully completed and that the product complies with the documentation and standard(s). The contents of electronic reports/certificates cannot be guaranteed. Original certification documents will be kept on file at Explolabs (Pty) Ltd

DOCUMENT No: XPL0213 RELEASE DATE: 29/05/2018